

Questions & Answers
SP0600-04-R-0097
Keesler Air Force Base, Mississippi

Question : Table 1 apparently shows a 2001 installation date for the two hospital transformers and associated 25KV switchgear, please confirm approximate age of the equipment at the hospital which is to be privatized?

Response: Based on a doublecheck by the Base exterior electric shop the age of the hospital transformers and switchgear referenced is approx 1978.